



March 24, 2025

## Corporation of the Municipality of Callander

### Request for Tender # 2025-02

# SWALE STREET RECONSTRUCTION

## ADDENDUM NO. #1

Please note the following clarifications to the above noted Request for Quotation:

1. Pavement Markings, Item 4.04 – The existing pavement markings on Swale Street are limited to durable stop bars at the intersections only. The successful contractor will only be required to replace these marking if removed during final paving.
2. Water Service to Community Centre – The existing water service to the Community Centre is assumed to be 50mm and served off of the existing hydrant branch. Any change to the arrangement will be negotiated as a potential Contract Change Order during construction.
3. Retaining Walls – The driveway retaining walls, as shown on the drawings, for Municipal Numbers 90, 100 and 164 are to be negotiated with the contractor as a potential Contract Change Order. At the time of Tender there exists too many options of material and final design of potential options for these small walls.
4. Sidewalk Tactile Indicators – The sidewalk for this project (Item 3.04) shall be designed to OPSS MUNI 351 and shall include all required Tactile Indicators to OPSD 310.039. Tactile Indicator pads will be required on both sides of Avenue A and King Street intersections only unless otherwise directed. The cost of the Tactile Indicators shall be included in the overall unit pricing for this item.

All other terms and conditions of the Tender Documents shall remain in full force and effect

Municipality of Callander  
280 Main Street North, P.O. Box 100  
Callander, Ontario  
POH 1H0  
Tel: (705) 752-1410 x 222